

CERTIFICATE OF ANALYSIS

Airborne Fibre Count

Certificate No: 18-8320

Client:	Environics	Dates Sampled:	20-02-2019 to 21-02-2019
Client Contact:	Lawrie Lyons	Date Received:	25-02-2019
Telephone:	0429 128 145	Date Analysed:	25-02-2019
Email:	lawrie-lyons@environics.com.au	Order No.:	FC0105+FC0106
Address:	U3, 12 Musgrave Crescent Coconut Grove NT 0810	Sampled By:	Lawrie Lyons (Environics)
Site:	Richmond Hospital QLD		

Test Method:

Filters examined in accordance with Safe Work Australia's Guidance Note on the Membrane Filter Method for the Estimation of Airborne Asbestos Fibres, 2nd Edition, 2005 [NOHSC:3003: (2005)] and COHLABS Laboratory Method MFM-1. The results contained within this report relate only to the sample(s) submitted for testing. COHLABS accepts no responsibility for the initial collection, packaging or transportation of samples submitted by external persons. This document may not be reproduced except in full.

Lab No.	Filter Id.	Sample Type	Sample Location	Fibre Count (Fibres/Field)	Concentration (Fibres/mL)
001	08	WT	20/02/19 - area 2	0 / 100	<0.01
002	09	WT	20/02/19 - area 3	0 / 100	<0.01
003	10	WT	20/02/19 - area 6	0 / 100	<0.01
004	11	WT	20/02/19 - area 1	0 / 100	<0.01
005	12	WT	20/02/19 - area 5	0 / 100	<0.02
006	13	WT	20/02/19 - area 4	0 / 100	<0.01
007	14	WT	21/02/19 - area 6 south	0 / 100	<0.01
008	15	WT	21/02/19 - area 2 adj road	0 / 100	<0.01
009	16	WT	21/02/19 - area 4 adj car park	0 / 100	<0.01
010	17	WT	21/02/19 - area 6 east	0 / 100	<0.01
011	18	WT	21/02/19 - area 1 north	0 / 100	<0.01

Sample Types

BT	Background Air Test	PT	Personal Air Test
WT	Work-in-Progress Air Test	WT / CT	Work-in-Progress/Clearance Air Test
CT	Clearance Air Test	RT	Reassurance Air Test
CFB	Client Field Blank		



NATA Accreditation number: 19499

Accredited for compliance with ISO/IEC: 17025. The results of tests, calibrations, and or measurements included in this document are traceable to Australian/national standards.

ABN: 62 166 540 094

Volume measurement performed by trained third party. COHLABS is responsible for the data.

Approved Counter

Name: Rachel Costa



Approved Signatory

Name: Rachel Costa



Notes:

If the fibre count is less than 10 fibres per 100 fields the count is not significantly above that of background (Guidance Note on the Membrane Filter Method for the Estimation of Airborne Asbestos Fibres, 2nd Edition, 2005 [NOHSC:3003: (2005)]).

Samples are routinely disposed of approximately 1 month from receipt. Requests for longer term sample storage must be received in writing.



NATA Accreditation number: 19499

Accredited for compliance with ISO/IEC: 17025. The results of tests, calibrations, and or measurements included in this document are traceable to Australian/national standards.

ABN: 62 166 540 094