

Suite 2, 92 Cleveland Street Greenslopes, QLD 4120 PO Box 45, Stones Corner, QLD 4120 Tel. +61 (0)7 3015 7555

# **CERTIFICATE OF ANALYSIS**

# **Airborne Fibre Count**

Certificate No: 18-8507

Client: 28-02-2019 **Environics Date Sampled: Client Contact:** Lawrie Lyons **Date Received:** 4-03-2019 **Date Analysed:** 4-03-2019 Telephone: 0429 128 145 Email: lawrie-lyons@environics.com.au Order No.: FC0111 Address: As Received U3, 12 Musgrave Crescent Sampled By:

Coconut Grove NT 0810

Site: Richmond Hospital QLD

#### **Test Method:**

Filters examined in accordance with Safe Work Australia's Guidance Note on the Membrane Filter Method for the Estimation of Airborne Asbestos Fibres, 2nd Edition, 2005 [NOHSC:3003: (2005)] and COHLABS Laboratory Method MFM-1. The results contained within this report relate only to the sample(s) submitted for testing. COHLABS accepts no responsibility for the initial collection, packaging or transportation of samples submitted by external persons. This document may not be reproduced except in full.

Lab No.	Filter Id.	Sample Type	Sample Location	Fibre Count (Fibres/Field)	Concentration (Fibres/mL)
001	41	WT	Adj LPG	0 / 100	<0.01
002	42	WT	Adj LPG	0 / 100	<0.01
003	43	WT	Adj table	0 / 100	<0.01
004	44	WT	Adj water tanks	0 / 100	<0.01

## Sample Types

BT Background Air Test PT Personal Air Test

WT Work-in-Progress Air Test WT / CT Work-in-Progress/Clearance Air Test

CT Clearance Air Test RT Reassurance Air Test

CFB Client Field Blank

NATA accreditation does not cover third party volume measurement.

**Approved Counter** 

Name: Michael Shepherd

**Approved Signatory** 

Name: Michael Shepherd

### Notes:

If the fibre count is less than 10 fibres per 100 fields the count is not significantly above that of background (Guidance Note on the Membrane Filter Method for the Estimation of Airborne Asbestos Fibres, 2nd Edition, 2005 [NOHSC:3003: (2005)]).

Samples are routinely disposed of approximately 1 month from receipt. Requests for longer term sample storage must be received in writing.



NATA Accreditation number: 19499

Accredited for compliance with ISO/IEC: 17025. The results of tests, calibrations, and or measurements included in this document are traceable to Australian/national standards.

ABN: 62 166 540 094